Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM305

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MILLER, JONAS J-LINE WOODCRAFT	Phone #: (608)269-1409
Mailing Address: W102 STATE RD 16	
City: SPARTA	State: WI — Zip Code: 54656

County	Co. Permit #	Notification #	Completed
La Crosse	2026-026	10199971801	03-25-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
OIUM, KELLY WELL DRILLING INC	8217	

Address: N50021 MISSELL ROAD, STRUM WI 54770

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		4.6

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): W106

Town of BURNS

Street Address or Road Name and Number: STATE RD 16

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)		Method Code
43.92817 °N	-90.91353 °W	GPS008

NE or Govt Lot #	NE	Section	Township	Range
		25	17 N	5 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
LACK OF WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	S		T-TAN/BROWN N-FINE S-SAND	Surface	3
T	A	S		T-TAN/BROWN A-COARSE S-SAND	3	40
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	40	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	VICTOR PIPE & STEEL 6.620XA53B.280 EWTC	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT JOHNSON STAINLESS STEEL SCREEN	57	60

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	57	3 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 23 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
OWNER IS KEEPING EXISTING

Filled & Sealed Well(s) as needed? No
OWNER IS KEEPING EXISTING

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO	6244	04-13-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JG	8980	04-13-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		36	Animal Barn or Barn Pen		59

Comment:

Created On: 03-25-2026 Updated On: 05-06-2026 Review Status: APPROVED