Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM318

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	LEITERMANN, KEVIN
Phone #	
Mailing Address	431 GOLDEN CEDAR LN
City	OCONOMOWOC
State	WI
Zip Code	53066
County	Waukesha
Co. Permit #	
Notification #	10167472401
Completed	03-12-2026
Well Constructor (Business Name)	D & D WELL & PUMPS LLC
Lic. #	7181
Facility ID # (Public Wells)	
Address	N6331 COUNTY F OCONOMOWOC WI 53066
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1.4

1. Well Location

Village of	SUMMIT
Fire # (if avail.)	
Street Address or Road Name and Number	431 N GOLDEN CEDAR LN
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.03877 °N -88.53524 °W
Method Code	GPS008
NE SW or Govt Lot #	
Section	30
Township	7 N
Range	17 E

2. Well Type Replacement

of previous unique well # RF116 constructed in 2003

Reason for replaced or reconstructed well ?

ADDITION

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	158

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	4
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	4	15
G		S	M	G-GRAY S-SAND M-SILTY	15	63
G		Z		G-GRAY Z-CLAY & GRAVEL	63	81
		L		L-LIMESTONE/DOLOMITE	81	158

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97# , A53-B, NUCOR & WELDED	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJ	5694	03-25-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		45	POWTS dispersal component (soil absorption unit or mound)		65
			Sewer - Building Sanitary		50

Comment:

Created On: 03-25-2026 Updated On: 10-15-2026 Review Status: APPROVED