

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM319		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																			
Property Owner GROSKREUTZ					Phone #		1. Well Location Fire # (if avail.) S1125 Town of LA VALLE Street Address or Road Name and Number SIOUX CT LAVALLE, WI 53941																						
Mailing Address S1143 E REDSTONE DR																													
City LAVALLE			State WI		Zip Code 53941		Subdivision Name Lot # Block #																						
County Sauk		Co. Permit #		Notification # 10060877101		Completed 12-17-2025																							
Well Constructor (Business Name) MCAFEE WELL DRLG & PUMP SERV INC			Lic. # 6829		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.60414 °N -90.08727 °W				Method Code OTH001																		
Address PO BOX 106 LA VALLE WI 53941			Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SW		Section 13		Township 13 N		Range 3 E																
							or Govt Lot #																						
Hicap Permanent Well #			Common Well #		Specific Capacity 0.7		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																						
3. Well serves 1 # of SHED Private, potable Heat Exchange ___ # of drillholes			Hicap Well ? No Hicap Property ? No Hicap Potable ? No																										
4. Potential Contamination Sources - ON REVERSE SIDE																													
5. Drillhole Dimensions and Construction Method																													
Dia. (in.) From (ft.) To (ft.) 8.5 Surface 50 6 50 81			Upper Enlarged Drillhole Lower Open Bedrock No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 8.5in. dia... No No Dual Rotary No Yes Temp. Outer Casing 8.5in. dia Yes Removed? 48depth ft. (If NO explain on back side)			8. Geology <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="3">Geology Codes</th> <th>Type, Caving/Noncaving, Color, Hardness, etc...</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> <tr> <td>T</td> <td>Q</td> <td>X</td> <td>T-TAN/BROWN Q-CAVING X-SAND & CLAY</td> <td>Surface</td> <td>48</td> </tr> <tr> <td>T</td> <td>M</td> <td>N</td> <td>T-TAN/BROWN M-MEDIUM N-SANDSTONE</td> <td>48</td> <td>81</td> </tr> </table>						Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	T	Q	X	T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	48	T	M	N	T-TAN/BROWN M-MEDIUM N-SANDSTONE	48	81
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																								
T	Q	X	T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	48																								
T	M	N	T-TAN/BROWN M-MEDIUM N-SANDSTONE	48	81																								
6. Casing, Liner, Screen <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Dia. (in.)</th> <th>Material, Weight, Specification Manufacturer & Method of Assembly</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> <tr> <td>6</td> <td>USA PLAIN END WELDED JOINT ASTM A53B 6.625 X 280. EL 21</td> <td>Surface</td> <td>50</td> </tr> <tr> <th>Dia. (in.)</th> <th>Screen type, material & slot size</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </table>						Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	6	USA PLAIN END WELDED JOINT ASTM A53B 6.625 X 280. EL 21	Surface	50	Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)					9. Static Water Level 25 ft. below ground surface			11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																										
6	USA PLAIN END WELDED JOINT ASTM A53B 6.625 X 280. EL 21	Surface	50																										
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																										
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Kind of Sealing Material</th> <th>From (ft.)</th> <th>To (ft.)</th> <th># Sacks Cement</th> </tr> <tr> <td>NEAT CEMENT GROUT</td> <td>Surface</td> <td>50</td> <td>32 S</td> </tr> </table>						Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement	NEAT CEMENT GROUT	Surface	50	32 S	10. Pump Test Pumping level 39 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ? Other			12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No												
Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement																										
NEAT CEMENT GROUT	Surface	50	32 S																										
13. Constructor / Supervisory Driller Lic # 6112 Date Signed 03-25-2026 Drill Rig Operator Lic or Reg # Date Signed																													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 03-25-2026

Updated On: 04-21-2026

Review Status: APPROVED