

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM321		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BECKER, TIM						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 2443 RUSSEL CT								Town of REEDSBURG				E7165							
City REEDSBURG						State WI		Zip Code 53959				Street Address or Road Name and Number COPPER CREEK WAY REEDSBURG, WI 53959							
County Sauk		Co. Permit #		Notification # 10123149701		Completed 02-03-2026		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) MCAFFEE WELL DRLG & PUMP SERV INC				Lic. # 6829		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.55216 °N -89.96074 °W				Method Code OTH001					
Address PO BOX 106 LA VALLE WI 53941				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 1 12 N 4 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)				
8.5 Surface 81			No Rotary - Mud Circulation No						T Q S			T-TAN/BROWN Q-CAVING S-SAND			Surface 11				
6 81 102			No Rotary - Air No						T M N			T-TAN/BROWN M-MEDIUM N-SANDSTONE			11 102				
			No Rotary - Air & Foam No																
			No Drill-Through Casing Hammer Reverse Rotary																
			Yes Cable-tool Bit 8.5in. dia... No																
			No Dual Rotary No																
			Yes Temp. Outer Casing 8.5in. dia																
			Yes Removed? 11depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		19 ft. below ground surface				36 in. above grade							
6		USA PLAIN END WELDED JOINT ASTM A53B. 6.625 X 280. EL 21. DRIVESHOE INSTALLED				Surface 81		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 34 ft. below surface				Disinfected ? Yes							
								Pumping at 10 GP M for 1 Hrs.				Capped ? Yes							
								Pumping Method ? Other											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED														Filled & Sealed Well(s) as needed? No					
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GROUT				Surface 81 20 S						TM				6112		03-25-2026			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		110	POWTS dispersal component (soil absorption unit or mound)		105

Comment:

Created On: 03-25-2026

Updated On: 04-21-2026

Review Status: APPROVED