Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM321

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BECKER, TIM			Phone #
Mailing Address: 2443 RUSSEL CT			
City: REEDSBURG	State: WI	Zip Code: 53959	
County: Sauk	Co. Permit #:	Notification #: 10123149701	Completed: 02-03-2026

Well Constructor (Business Name): MCAFEE WELL DRLG & PUMP SERV INC	Lic. #: 6829	Facility ID # (Public Wells):	
Address: PO BOX 106 LA VALLE WI 53941		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

1. Well Location

Town of REEDSBURG

Fire # (if avail.): E7165

Street Address or Road Name and Number: COPPER CREEK WAY REEDSBURG, WI 53959

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.55216 °N -89.96074 °W	OTH001

NW NE or Govt Lot #	Section	Township	Range
	1	12 N	4 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	81
6	81	102

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 8.5in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8.5in. dia	
Yes	Removed? 11depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	11
T	M	N		T-TAN/BROWN M-MEDIUM N-SANDSTONE	11	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	USA PLAIN END WELDED JOINT ASTM A53B. 6.625 X 280. EL 21. DRIVESHOE INSTALLED	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Other

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	81	20 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM	6112	03-25-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		110	POWTS dispersal component (soil absorption unit or mound)		105

Comment:

Created On: 03-25-2026 Updated On: 10-15-2026 Review Status: APPROVED