

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM324		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner MUELLER THEODORE					Phone #		1. Well Location Fire # (if avail.) Town of MONTPELIER E1762 Street Address or Road Name and Number CHURCH RD				Subdivision Name Lot # Block #	
Mailing Address N1150 WOODSIDE RD												
City KEWAUNEE			State WI		Zip Code 54216		Latitude / Longitude in Decimal Degree (DD) 44.47331 °N -87.68028 °W Method Code GPS008					
County Kewaunee		Co. Permit #		Notification # 10198646401		Completed 03-26-2026						
Well Constructor (Business Name) RETZLAFF & GREGORICH				Lic. # 7267		Facility ID # (Public Wells)		SW SW Section Township Range or Govt Lot # 11 23 N 23 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled		
Address WELL DRILLING LLC 5861 MARY'S RD NEW FRANKEN WI 54229						Well Plan Approval #						
						Approval Date (mm-dd-yyyy)						
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)			
10	Surface	9	No Rotary - Mud Circulation				No		B L S B-BROKEN L-LIMESTONE/DOLOMITE S-SANDY Surface 7			
8	9	103	Yes Rotary - Air				Yes					
6	103	223	No Rotary - Air & Foam				No		L L-LIMESTONE/DOLOMITE 7 223			
			No Drill-Through Casing Hammer									
			No Reverse Rotary									
			No Cable-tool Bit ___ in. dia...				No					
			No Dual Rotary				No					
			Yes Temp. Outer Casing 8in. dia									
			Yes Removed? 9depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	9. Static Water Level 88 ft. below ground surface 10. Pump Test Pumping level 160 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Airlift					
6	NUCOR ASTM A53-B 6.625IN X 0.280IN PE WELDED JOINT MADE IN USA				Surface	105						
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material												
Method BRADENHEAD												
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement							
NEAT PORTLAND CEMENT			Surface	103	34 S							
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
KG						6985		03-30-2026				
Drill Rig Operator						Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		165	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 03-25-2026

Updated On: 04-21-2026

Review Status: APPROVED