Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM324

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MUELLER THEODORE	Phone #
Mailing Address: N1150 WOODSIDE RD	
City: KEWAUNEE	State: WI — Zip Code: 54216
County: Kewaunee	Co. Permit #: — Notification #: 10198646401 — Completed: 03-26-2026
Well Constructor (Business Name): RETZLAFF & GREGORICH	Lic. #: 7267 — Facility ID # (Public Wells):
Address: WELL DRILLING LLC 5861 MARY'S RD NEW FRANKEN WI 54229	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of MONTPELIER	Fire # (if avail.): E1762
Street Address or Road Name and Number: CHURCH RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.47331 °N -87.68028 °W	Method Code: GPS008
SW SW or Govt Lot #: — Section: 11 — Township: 23 N — Range: 23 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
8	9	103
6	103	223

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 9depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	B	L	S	B-BROKEN L-LIMESTONE/DOLOMITE S-SANDY	Surface	7
		L		L-LIMESTONE/DOLOMITE	7	223

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCOR ASTM A53-B 6.625IN X 0.280IN PE WELDED JOINT MADE IN USA	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
88 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT PORTLAND CEMENT	Surface	103	34 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG	6985	03-30-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		165	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 03-25-2026 Updated On: 04-21-2026 Review Status: APPROVED