Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM335

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, KURTIS	Phone #
Mailing Address: PO BOX 147	
City: WAUTOMA	State: WI — Zip Code: 54982
County: Waushara	Co. Permit #: — Notification #: 10161310801 — Completed: 03-10-2026

1. Well Location

Town of MOUNT MORRIS — Fire # (if avail.): N3266

Street Address or Road Name and Number: PINE LANE

Subdivision Name: — Lot #: — Block #:

Well Constructor (Business Name): JENKS, TIMOTHY J	Lic. #: 4458 — Facility ID # (Public Wells):
Address: JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.1

Latitude / Longitude in Decimal Degree (DD): 44.09685 °N -89.22634 °W — Method Code: SCR002

NW NW or Govt Lot # — Section: 29 — Township: 19 N — Range: 11 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	68

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	35
T	W	S	C	T-TAN/BROWN W-WATER BEARING S-SAND C-CLAYEY	35	56
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	56	68

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B P.E WELDED 18.97#/FT 1780 HYDRO	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	8 SLOT SS	65	68

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface
Pumping at 25 GP M for 1.5 Hrs.
Pumping Method ? Other

11. Well Is

20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1.5 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ	4458	03-20-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 03-26-2026 Updated On: 04-21-2026 Review Status: APPROVED