

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM335		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JOHNSON, KURTIS						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 147						Town of MOUNT MORRIS						N3266					
City WAUTOMA						State WI		Zip Code 54982				Street Address or Road Name and Number PINE LANE					
County Waushara		Co. Permit #		Notification # 10161310801		Completed 03-10-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) JENKS, TIMOTHY J				Lic. # 4458		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.09685 °N -89.22634 °W				Method Code SCR002			
Address JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 29 19 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		68		No Rotary - Mud Circulation		No		T Q Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL		Surface		35	
						No Rotary - Air		No		T W S C		T-TAN/BROWN W-WATER BEARING S-SAND C-CLAYEY		35		56	
						No Rotary - Air & Foam		No		T W S		T-TAN/BROWN W-WATER BEARING S-SAND		56		68	
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 25 ft. below ground surface				11. Well Is 20 in. above grade			
6		WHEATLAND A53B P.E WELDED 18.97#/FT 1780 HYDRO				Surface		65		10. Pump Test Pumping level 37 ft. below surface Pumping at 25 GP M for 1.5 Hrs. Pumping Method ? Other				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		8 SLOT SS				65		68									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE				Surface				1.5 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
TJ												4458		03-20-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 03-26-2026

Updated On: 04-21-2026

Review Status: APPROVED