Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM371

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VRANY, DAVID	Phone #
Mailing Address: 1112 N WESTSHORE DR	
City: OCONOMOWOC	State: WI — Zip Code: 53066
County: Waukesha	Co. Permit #: — Notification #: 10190574401 — Completed: 03-26-2026
Well Constructor (Business Name): ROSCHI BROS WELL DRLG & PUMP INC	Lic. #: 435 — Facility ID # (Public Wells):
Address: N10W28210 NORTHVIEW RD WAUKESHA WI 53188-9401	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.7

1. Well Location

Village of SUMMIT	Fire # (if avail.):
Street Address or Road Name and Number: 1112 N WESTSHORE DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.0465 °N -88.4845 °W	Method Code: GPS008
NE NE or Govt Lot #: — Section: 28 — Township: 7 N — Range: 17 E	

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	304

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	C	Y-SAND & GRAVEL C-CLAYEY	Surface	12
		Y		Y-SAND & GRAVEL	12	19
G	A	S		G-GRAY A-COARSE S-SAND	19	22
G	F	S		G-GRAY F-FRACTURED S-SAND	22	125
		C		C-CLAY	125	128
		X		X-SAND & CLAY	128	194
		C	S	C-CLAY S-SANDY	194	298
		Z		Z-CLAY & GRAVEL	298	300
		Y		Y-SAND & GRAVEL	300	304

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18.97LB ASTM A53 1780PSI NUCOR	Surface	304
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level	11. Well Is
8 ft. below ground surface	12 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 14 ft. below surface	Disinfected ? Yes
Pumping at 16 GP M for 3.5 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TK	6203	03-26-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EK	8767	03-26-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		53

Comment:

Created On: 03-30-2026 Updated On: 04-21-2026 Review Status: APPROVED