Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM411

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BREDL, STEPHANEY			Phone #
Mailing Address: 544 TRESSERVILLE RD			
City: NEKOOSA	State: WI	Zip Code: 54457	
County: Wood	Co. Permit #: W26017	Notification #: 10201681001	Completed: 03-30-2026

Well Constructor (Business Name): ROCK SOLID WELL DRILLING LLC	Lic. #: 9321	Facility ID # (Public Wells)
Address: 531 STATE HIGHWAY 73 NEKOOSA WI 54457		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.3

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of SARATOGA

Fire # (if avail.): 544

Street Address or Road Name and Number: TESSERVILLE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.3057 °N -89.8786 °W	SCR002

NE	NW	Section	Township	Range
or Govt Lot #		14	21 N	5 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL DIDN'T MAKE ENOUGH WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	55

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S. S. #18	49	55

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
20% SOLID PUMPABLE BENT	Surface	47	7 S
SAND PACK	47	49	2 S
RED FLINT GRAVEL PACK #30	49	55	4 S

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JP	9099	04-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JP	9099	04-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75

Comment:

Created On: 03-31-2026 Updated On: 10-15-2026 Review Status: APPROVED