

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM411		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BREDL, STEPHANEY					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 544 TRESSERVILLE RD							Town of SARATOGA				544		
City NEKOOSA					State WI		Zip Code 54457		Street Address or Road Name and Number				
TESSERVILLE RD													
County Wood		Co. Permit # W26017		Notification # 10201681001		Completed 03-30-2026		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
ROCK SOLID WELL DRILLING LLC				9321				44.3057 °N -89.8786 °W				SCR002	
Address 531 STATE HIGHWAY 73 NEKOOSA WI 54457				Well Plan Approval #		NE NW		Section 14		Township 21 N		Range 5 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity		0		2. Well Type Replacement					
								of previous unique well # constructed in					
								Reason for replaced or reconstructed well ?					
								OLD WELL DIDN'T MAKE ENOUGH WATER					
3. Well serves 1 # of HOME				Hicap Well ? No				Construction Type Drilled					
Private,potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
9		Surface		55						Geology Codes			
						Yes Rotary - Mud Circulation		No		Type, Caving/Noncaving, Color, Hardness, etc...			
						No Rotary - Air		No		Y			
						No Rotary - Air & Foam		No		Y-SAND & GRAVEL			
						No Drill-Through Casing Hammer				From (ft.)			
						No Reverse Rotary				Surface			
						No Cable-tool Bit ___ in. dia...		No		To (ft.)			
						No Dual Rotary		No		55			
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is			
5		F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED				Surface		49		16 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes			
5		S. S. #18				49		55		Disinfected ? Yes			
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test					
20% SOLID PUMPABLE BENT		Surface		47		7 S		Pumping level 45 ft. below surface					
SAND PACK		47		49		2 S		Pumping at 20 GP M for 1 Hrs.					
RED FLINT GRAVEL PACK #30		49		55		4 S		Pumping Method ? Airlift					
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
JP		Lic #		9099		Date Signed		04-05-2026					
Drill Rig Operator		Lic or Reg #		9099		Date Signed		04-05-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75

Comment:

Created On: 03-31-2026

Updated On: 04-23-2026

Review Status: APPROVED