

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM422		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RICE, SHANE						Phone # (715)680-8530		1. Well Location				Fire # (if avail.)									
Mailing Address W2752 HIGHWAY 86						Town of HILL						W2752									
City OGEMA						State WI		Zip Code 54459				Street Address or Road Name and Number HIGHWAY 86									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Price				10189875701		03-31-2026															
Well Constructor (Business Name) KOMAREK, RONALD A SR				Lic. # 610		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.45672 °N -90.17857 °W				Method Code GPS008							
Address N1690 STATE HIGHWAY 13 OGEMA WI 54459				Well Plan Approval #				SE SW		Section 1		Township 34 N		Range 2 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 3				2. Well Type New Well				of previous unique well #		constructed in					
										Reason for replaced or reconstructed well ?											
3. Well serves 1 # of FUTURE HOME				Hicap Well ? No																	
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No						Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		240		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						C		C-CLAY		Surface		57			
												G U		G-GRAVEL/STONES U-MUDDY OR MURKY		57		58			
												C S		C-CLAY S-SANDY		58		164			
												C G		C-CLAY G-W/GRAVEL/STONES		164		199			
												G U		G-GRAVEL/STONES U-MUDDY OR MURKY		199		239			
												E G		E-CLEAN G-GRAVEL/STONES		239		240			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		29 ft. below ground surface				28 in. above grade							
6		.280 ASTM A53B, 18.97# WEDT JT, WHEATLAND				Surface		240		10. Pump Test				Developed ? Yes							
										Pumping level 35 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 18 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
GRANULAR BENTONITE				Surface																	
13. Constructor / Supervisory Driller														Lic #		Date Signed					
RJK														6961		04-09-2026					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-01-2026

Updated On: 05-04-2026

Review Status: APPROVED