Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM423

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WONDRA, SHANE AND AMY	Phone #: (920)450-5269
Mailing Address: N9060 OAK ROAD	
City: PICKETT	State: WI — Zip Code: 54964
County: Price	Co. Permit #:
Notification #: 10193482301	Completed: 03-30-2026
Well Constructor (Business Name): KOMAREK, RONALD A SR	Lic. #: 610
Facility ID # (Public Wells):	
Address: N1690 STATE HIGHWAY 13 OGEMA WI 54459	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Town of OGEMA	Fire # (if avail.): W5214
Street Address or Road Name and Number: HIGHWAY 86	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.4467 °N -90.306 °W	Method Code: GPS008
SW NW or Govt Lot #:	Section: 12 — Township: 34 N — Range: 1 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: DUG WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	127

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	8
		G		G-GRAVEL/STONES	8	11
		C		C-CLAY	11	44
		Y	U	Y-SAND & GRAVEL U-MUDDY OR MURKY	44	47
	X	X		X-LENSED/STREAKED/LAYERED X-SAND & CLAY	47	87
		C		C-CLAY	87	120
		Y		Y-SAND & GRAVEL	120	127

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.6	.280 ASTM A53B, 18.97# WEDT JT, WHEATLAND	Surface	123
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	15 SLOT SS JOHNSON	123	127

9. Static Water Level

4 ft. above ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 6 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJK	6961	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-01-2026 Updated On: 05-04-2026 Review Status: APPROVED