

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM423		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WONDRA, SHANE AND AMY					Phone # (920)450-5269		1. Well Location				Fire # (if avail.)								
Mailing Address N9060 OAK ROAD							Town of OGEMA				W5214								
City PICKETT					State WI		Zip Code 54964				Street Address or Road Name and Number HIGHWAY 86								
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #							
Price				10193482301		03-30-2026						Block #							
Well Constructor (Business Name) KOMAREK, RONALD A SR				Lic. # 610		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.4467 °N -90.306 °W				Method Code GPS008							
Address N1690 STATE HIGHWAY 13 OGEMA WI 54459				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 12 34 N 1 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? DUG WELL											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2															
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		127		No Rotary - Mud Circulation		No		C		C-CLAY		Surface		8			
						No Rotary - Air		No		G		G-GRAVEL/STONES		8		11			
						No Rotary - Air & Foam		No		C		C-CLAY		11		44			
						No Drill-Through Casing Hammer				Y U		Y-SAND & GRAVEL U-MUDDY OR MURKY		44		47			
						No Reverse Rotary				X X		X-LENSED/STREAKED/LAYERED X-SAND & CLAY		47		87			
						No Cable-tool Bit ___ in. dia...		No		C		C-CLAY		87		120			
						No Dual Rotary		No		Y		Y-SAND & GRAVEL		120		127			
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		4 ft. above ground surface				24 in. above grade					
6.6		.280 ASTM A53B, 18.97# WEDT JT, WHEATLAND				Surface		123		10. Pump Test Pumping level 35 ft. below surface Pumping at 6 GP M for 2 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
4		15 SLOT SS JOHNSON				123		127											
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
GRANULAR BENTONITE				Surface															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RJK				6961		04-09-2026	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-01-2026

Updated On: 05-04-2026

Review Status: APPROVED