Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM424

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ENNIS, DANIEL			Phone #
Mailing Address: 1930 42ND ST SOUTH			
City: WISCONSIN RAPIDS	State: WI	Zip Code: 54494	
County: Wood	Co. Permit #: w26019	Notification #: 10191761401	Completed: 03-20-2026

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.): 1930

Street Address or Road Name and Number: 1930 42ND ST SOUTH

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): DJ'S WATER SERVICE	Lic. #: 7072	Facility ID # (Public Wells)	
Address: 6522 OAK DR AMHERST WI 54406		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.8	

Latitude / Longitude in Decimal Degree (DD): 44.3739 °N -89.7736 °W

Method Code: GPS008

SW	NE	Section	Township	Range
or Govt Lot #		22	22 N	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

WELL TOO CLOSE TO NEW SEPTIC

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	28

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	1
		S		S-SAND	1	6
		Y		Y-SAND & GRAVEL	6	28

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A53B 18.97 WHEATLAND WELD	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	3FT 20 SLOT STAINLESS STEEL TELESCOPING	25	28

9. Static Water Level

9.8 ft. below ground surface

10. Pump Test

Pumping level 15.7 ft. below surface

Pumping at 16.5 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	25	1 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJFJ	6760	03-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JDF	9478	03-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment: RECEIVED VERBAL VARIANCE FROM ADAM SCHEUNEMANN ON 3/18/2026

Variance ID	Variance or Exception Type	Date	Reason
	WCR Submit Time	03/20/2026	NEEDED VARIANCE, RECEIVED 04/21 AND COUNTY, RECEIVED ON 04/22
85162	Separation Distance Variance	04/21/2026	SEPERATION DISTANCE FROM OLD SEPTIC

Created On: 04-01-2026 Updated On: 05-05-2026 Review Status: APPROVED