Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM432

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FINGER DAVID	Phone #
Mailing Address: 1285 WHITE EAGLE LN	
City: HUDSON	State: WI — Zip Code: 54016
County: St. Croix	Co. Permit #: — Notification #: 10141904401 — Completed: 03-12-2026
Well Constructor (Business Name): STEVE'S WELL AND PUMP SERVICES, LLC	Lic. #: 8260 — Facility ID # (Public Wells):
Address: 499 192ND AVE SOMERSET WI 54025	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of ST. JOSEPH	Fire # (if avail.): 1285
Street Address or Road Name and Number: WHITE EAGLE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.04844 °N -92.72805 °W	Method Code: SCR002

NW or Govt Lot #	NE	Section	Township	Range
		31	30 N	19 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	281

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	10
T	A	S		T-TAN/BROWN A-COARSE S-SAND	10	281

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE 18.99 LBS FT WELDED ASTM	Surface	278
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	JOHNSON 12 SLOT SS	278	281

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	278	10 S

9. Static Water Level

220 ft. below ground surface

10. Pump Test

Pumping level 250 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SF	6412	04-01-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		125	POWTS dispersal component (soil absorption unit or mound)		140

Comment:

Created On: 04-01-2026 Updated On: 10-15-2026 Review Status: APPROVED