Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM434

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SIMONSON, ALLAN	Phone #
Mailing Address: N9408 W. ALMA RD	
City: HIXTON	State: WI — Zip Code: 54635

County	Co. Permit #	Notification #	Completed
Jackson	25041-1	10142921701	02-18-2026

1. Well Location

Town of HIXTON

Fire # (if avail.): N9408

Street Address or Road Name and Number: W ALMA RD

Subdivision Name | Lot # | Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RUSH, JON A	5837	

Latitude / Longitude in Decimal Degree (DD): 44.4106 °N -90.932 °W — Method Code: GPS008

Well Plan Approval #

SW	SE	Section	Township	Range
or Govt Lot #		1	22 N	5 W

Address: RUSH WELL DRLG LLC N7570 ODEEN ROAD
BLACK RIVER FALLS WI 54615

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # — constructed in

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.8

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	100

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 12depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	12
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	12	65
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	65	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97#/FT ASTMA53B WHEATLAND,WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

62 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	23 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR	5837	04-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JAR		04-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		60	POWTS dispersal component (soil absorption unit or mound)		75

Comment:

Created On: 04-01-2026 Updated On: 10-15-2026 Review Status: APPROVED