Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM435

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCNULTY FARMS	Phone #
Mailing Address: N5183 MATSON RD	
City: BLACK RIVER FALLS	State: WI Zip Code: 54615

County	Co. Permit #	Notification #	Completed
Jackson	26069-2	10200189201	04-01-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RUSH, JON A	5837	

Address: RUSH WELL DRLG LLC N7570 ODEEN ROAD
BLACK RIVER FALLS WI 54615

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves # of FARM

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ALBION

Fire # (if avail.): N5183

Street Address or Road Name and Number: N5183 MATSON RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.2568 °N -90.8952 °W	GPS008

SE NW or Govt Lot #	Section	Township	Range
	32	21 N	4 W

2. Well Type Replacement

of previous unique well # MF957 constructed in 1997

Reason for replaced or reconstructed well ?

POOR LOCATION ON REPLACED WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	41
6	41	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 16depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	C		T-TAN/BROWN Q-CAVING C-CLAY	Surface	16
G	H	N		G-GRAY H-HARD/FIRM N-SANDSTONE	16	65
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	65	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97#/FT ASTMA53B WHEATLAND,WELDED	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT5	Surface	41	20 S

9. Static Water Level

65 ft. below ground surface

10. Pump Test

Pumping level 85 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

OLD WELL TO BE USED FOR BARN

Filled & Sealed Well(s) as needed? No

OLD WELL TO BE USED FOR BARN

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR	5837	04-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JAR		04-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 04-01-2026 Updated On: 10-15-2026 Review Status: APPROVED