# Well Construction Report
## WISCONSIN UNIQUE WELL NUMBER: ACM445

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner | GROSS POINT ACRES LLC |
| Phone # | |
| Mailing Address | 18310 79TH AVE |
| City | CHIPPEWA FALLS |
| State | WI |
| Zip Code | 54729 |
| County | Chippewa |
| Co. Permit # | 20260006 |
| Notification # | 10139182001 |
| Completed | 03-16-2026 |
| Well Constructor (Business Name) | OLSON KEN WELL DRLG & PUMP SER INC |
| Lic. # | 215 |
| Facility ID # (Public Wells) | |
| Address | 10224 20TH AVE<br>EAU CLAIRE WI 54703-0288 |
| Well Plan Approval # | |
| Approval Date (mm-dd-yyyy) | |
| Hicap Permanent Well # | |
| Common Well # | |
| Specific Capacity | 1.7 |

**1. Well Location**

| | |
|---|---|
| Fire # (if avail.) | 6579 |
| Town of | LAFAYETTE |
| Street Address or Road Name and Number | CTY HWY K |
| Subdivision Name | |
| Lot # | |
| Block # | |
| Latitude / Longitude in Decimal Degree (DD) | 44.93911 °N -91.26714 °W |
| Method Code | GPS008 |
| SW NW or Govt Lot # | |
| Section | 5 |
| Township | 28 N |
| Range | 7 W |

**2. Well Type** New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

**3. Well serves** 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 63 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| | | Y | | Y-SAND & GRAVEL | Surface | 35 |
| | | S | M | S-SAND M-SILTY | 35 | 50 |
| | | Y | S | Y-SAND & GRAVEL S-SANDY | 50 | 63 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | STEEL, NEW BLACK T&C; ASTM A53; .280 WALL; 19.45#/FT; WHEATLAND | Surface | 58 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 4 | MAASS STAINLESS MESH SANDBLOCKER II | 58 | 63 |

**9. Static Water Level**

33 ft. below ground surface

**10. Pump Test**

Pumping level 45 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

**11. Well Is**

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | | |

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| 13. Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| KDO | 6208 | 04-03-2026 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| TR | 9109 | 04-03-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 78 | Building Drain - Sanitary | | 20 |
| | | | Septic or Holding, or POWTS Tank | | 29 |

Comment:

Created On: 04-02-2026 Updated On: 04-28-2026 Review Status: APPROVED