

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM445		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GROSS POINT ACRES LLC						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 18310 79TH AVE								Town of LAFAYETTE				6579	
City CHIPPEWA FALLS						State WI		Zip Code 54729				Street Address or Road Name and Number	
County Chippewa						Co. Permit # 20260006		Notification # 10139182001				Completed 03-16-2026	
Well Constructor (Business Name) OLSON KEN WELL DRLG & PUMP SER INC						Lic. # 215		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.93911 °N -91.26714 °W	
Address 10224 20TH AVE EAU CLAIRE WI 54703-0288						Well Plan Approval #		SW NW		Section 5		Township 28 N	
								Range 7 W		Method Code GPS008			
Approval Date (mm-dd-yyyy)						or Govt Lot #		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #						Common Well #		Specific Capacity 1.7				Reason for replaced or reconstructed well ?	
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled					
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		63		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
Y		Y-SAND & GRAVEL		Surface		35							
S M		S-SAND M-SILTY		35		50							
Y S		Y-SAND & GRAVEL S-SANDY		50		63							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL, NEW BLACK T&C; ASTM A53; .280 WALL; 19.45#/FT; WHEATLAND				Surface		58					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		MAASS STAINLESS MESH SANDBLOCKER II				58		63					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface									
9. Static Water Level													
33 ft. below ground surface													
10. Pump Test													
Pumping level 45 ft. below surface													
Pumping at 20 GP M for 2 Hrs.													
Pumping Method ? Test Pump													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
KDO				6208				04-03-2026					
Drill Rig Operator				Lic or Reg #				Date Signed					
TR				9109				04-03-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		78	Building Drain - Sanitary		20
			Septic or Holding, or POWTS Tank		29

Comment:

Created On: 04-02-2026

Updated On: 04-28-2026

Review Status: APPROVED