

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM449		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner HENDRICKS, SCOT						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 281 OLD SCOUT CAMP TRL						Town of SOMERSET						280	
City HOULTON						State WI		Zip Code 54082				Street Address or Road Name and Number	
280 ANDERSEN SCOUT CAMP TRL						Subdivision Name				Lot #		Block #	
County St. Croix		Co. Permit #		Notification # 10105216701		Completed 03-06-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name)				Lic. # 105		Facility ID # (Public Wells)				45.09166 °N -92.74383 °W		SCR002	
MARTELL WELL DRILLING & PUMP REPAIR INC				Well Plan Approval #				NE NE		Section 13		Township 30 N	
Address PO BOX 28 SOMERSET WI 54025-0028				Approval Date (mm-dd-yyyy)				Range 20 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0				of previous unique well # constructed in			
3. Well serves 1 # of POLESHED				Hicap Well ? No				Reason for replaced or reconstructed well ?					
Private, potable				Hicap Property ? No				Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 103			Yes Rotary - Mud Circulation No										
6 103 320			No Rotary - Air Yes										
			No Rotary - Air & Foam No										
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			No Cable-tool Bit ___ in. dia... No										
			No Dual Rotary No										
			No Temp. Outer Casing ___ in. dia										
			No Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
Z			Z-CLAY & GRAVEL						Surface 30				
Y			Y-SAND & GRAVEL						30 100				
H N			H-HARD/FIRM N-SANDSTONE						100 320				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		18.99LBS PER FT ASTHMA 53 NEW PRIME PE				Surface 103							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material			From (ft.) To (ft.) # Sacks Cement										
20% HEAVY SOLIDS BENTONITE			Surface 103 10 S										
9. Static Water Level													
235 ft. below ground surface													
10. Pump Test													
Pumping level 250 ft. below surface													
Pumping at 20 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
MF			106 04-02-2026										
Drill Rig Operator			Lic or Reg # Date Signed										
MDF			8352 04-02-2026										

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-02-2026

Updated On: 04-28-2026

Review Status: APPROVED