

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM450		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HELLAND, MARCUS						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1851 WHITE PINE WAY						Town of ALDEN						1726			
City NEW RICHMOND						State WI		Zip Code 54017				Street Address or Road Name and Number			
1726 W CHURCH RD						Subdivision Name				Lot #		Block #			
County Polk		Co. Permit #		Notification # 10161128801		Completed 03-03-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name) MARTELL WELL DRILLING & PUMP REPAIR INC						Lic. # 105		Facility ID # (Public Wells)				45.23845 °N -92.51598 °W		SCR002	
Address PO BOX 28 SOMERSET WI 54025-0028						Well Plan Approval #		SW SE		Section 19		Township 32 N		Range 17 W	
								or Govt Lot #		19		32 N		17 W	
Approval Date (mm-dd-yyyy)						2. Well Type New Well									
Hicap Permanent Well #						Common Well #		Specific Capacity 1.3		of previous unique well #				constructed in	
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ?							
Private, potable						Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 142			Yes Rotary - Mud Circulation No												
6 142 145			No Rotary - Air Yes												
			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S C				S-SAND C-CLAYEY				Surface		10					
Y				Y-SAND & GRAVEL				10		95					
C				C-CLAY				95		105					
S C				S-SAND C-CLAYEY				105		135					
Y				Y-SAND & GRAVEL				135		145					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		18.99LBS PER FT ASTHMA 53 NEW PRIME PE				Surface		142							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
2		.12 SLOT SS SCREEN				142		145							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
20% HEAVY SOLIDS BENTONITE				Surface		142		14 S							
9. Static Water Level															
75 ft. below ground surface															
10. Pump Test															
Pumping level 90 ft. below surface															
Pumping at 15 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
MF				106 04-02-2026											
Drill Rig Operator				Lic or Reg #											
MDF				8352 04-02-2026											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-02-2026

Updated On: 04-28-2026

Review Status: APPROVED