Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM450

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	HELLAND, MARCUS
Phone #	
Mailing Address	1851 WHITE PINE WAY
City	NEW RICHMOND
State	WI
Zip Code	54017
County	Polk
Co. Permit #	
Notification #	10161128801
Completed	03-03-2026
Well Constructor (Business Name)	MARTELL WELL DRILLING & PUMP REPAIR INC
Lic. #	105
Facility ID # (Public Wells)	
Address	PO BOX 28 SOMERSET WI 54025-0028
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1

1. Well Location

Fire # (if avail.)	1726
Town of ALDEN	
Street Address or Road Name and Number	1726 W CHURCH RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	45.23845 °N -92.51598 °W
Method Code	SCR002
SW SE or Govt Lot #	
Section	19
Township	32 N
Range	17 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	142
6	142	145

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	C	S-SAND C-CLAYEY	Surface	10
		Y		Y-SAND & GRAVEL	10	95
		C		C-CLAY	95	105
		S	C	S-SAND C-CLAYEY	105	135
		Y		Y-SAND & GRAVEL	135	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.99LBS PER FT ASTHMA 53 NEW PRIME PE	Surface	142
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	.12 SLOT SS SCREEN	142	145

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
20% HEAVY SOLIDS BENTONITE	Surface	142	14 S

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MF	106	04-02-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MDF	8352	04-02-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-02-2026 Updated On: 10-15-2026 Review Status: APPROVED