Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM452

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KELLY			Phone #
Mailing Address: 6827 KINGSTON CIR N			
City: GOLDEN VALLEY	State: MN	Zip Code: 55427	
County: St. Croix	Co. Permit #:	Notification #: 10134983201	Completed: 03-30-2026

1. Well Location

Town of ST. JOSEPH

Fire # (if avail.): 1264

Street Address or Road Name and Number: 1264 COUNTY RD V

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): MARTELL WELL DRILLING & PUMP REPAIR INC	Lic. #: 105	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 45.04347 °N -92.74308 °W
		Well Plan Approval #	Method Code: SCR002
Address: PO BOX 28 SOMERSET WI 54025-0028		Approval Date (mm-dd-yyyy)	SE NE or Govt Lot #: Section: 36 Township: 30 N Range: 20 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME	Hicap Well ? No	Construction Type: Drilled
Private,potable	Hicap Property ? No	
Heat Exchange____# of drillholes	Hicap Potable ? No	

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	254
6	254	256

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	C	S-SAND C-CLAYEY	Surface	60
		Y		Y-SAND & GRAVEL	60	160
		Z		Z-CLAY & GRAVEL	160	235
		Y		Y-SAND & GRAVEL	235	256

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.99LBS PER FT ASTHMA 53 NEW PRIME PE	Surface	254
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	.12 SLOT SS SCREEN	254	256

9. Static Water Level

150 ft. below ground surface

10. Pump Test

Pumping level 175 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
20% HEAVY SOLIDS BENTONITE	Surface	254	22 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MF	106	04-02-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MDF	8352	04-02-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-02-2026 Updated On: 04-28-2026 Review Status: APPROVED