Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM459

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TAYLOR, KAYLYN	Phone #
Mailing Address: 205817 MORAINE RD	
City: HATLEY	State: WI — Zip Code: 54440
County: Marathon	Co. Permit #: — Notification #: 10190349801 — Completed: 03-23-2026
Well Constructor (Business Name): ROCK SOLID WELL DRILLING LLC	Lic. #: 9321 — Facility ID # (Public Wells):
Address: 531 STATE HIGHWAY 73 NEKOOSA WI 54457	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of BEVENT	Fire # (if avail.): 205817
Street Address or Road Name and Number: MORAINE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.7341 °N -89.3668 °W	Method Code: SCR002
SE NE or Govt Lot #: — Section: 14 — Township: 26 N — Range: 9 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: HIGH NITRATE AND WELL WAS NOT UP TO CODE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	42

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	A	Y		A-COARSE Y-SAND & GRAVEL	Surface	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S. S. #18	36	42

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
20% SOLID PUMPABLE BENT	Surface	34	7 S
SAND PACK	34	36	2 S
RED FLINT GRAVEL PACK #30	36	42	4 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 33 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JP	9099	04-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JP	9099	04-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		55

Comment:

Created On: 04-05-2026 Updated On: 10-15-2026 Review Status: APPROVED