

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM459		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner TAYLOR, KAYLYN					Phone #		1. Well Location Fire # (if avail.) 205817					
Mailing Address 205817 MORaine RD												
City HATLEY			State WI		Zip Code 54440		Town of BEVENT Street Address or Road Name and Number MORaine RD					
County Marathon		Co. Permit #		Notification # 10190349801		Completed 03-23-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) ROCK SOLID WELL DRILLING LLC				Lic. # 9321		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.7341 °N -89.3668 °W			Method Code SCR002	
Address 531 STATE HIGHWAY 73 NEKOOSA WI 54457				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 14 26 N 9 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? HIGH NITRATE AND WELL WAS NOT UP TO CODE				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0		Construction Type Drilled					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)		
9		Surface		42		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				A Y A-COARSE Y-SAND & GRAVEL Surface 42		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
5		F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED				Surface		36				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
5		S. S. #18				36		42				
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement					
20% SOLID PUMPABLE BENT			Surface		34		7 S					
SAND PACK			34		36		2 S					
RED FLINT GRAVEL PACK #30			36		42		4 S					
9. Static Water Level 15 ft. below ground surface												
10. Pump Test Pumping level 35 ft. below surface Pumping at 33 GP M for 1 Hrs. Pumping Method ? Test Pump												
12. Notified Owner of need to fill & seal ? Yes												
Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller				Lic #		Date Signed						
JP				9099		04-05-2026						
Drill Rig Operator				Lic or Reg #		Date Signed						
JP				9099		04-05-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		55

Comment:

Created On: 04-05-2026

Updated On: 04-29-2026

Review Status: APPROVED