

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM460		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner DAVIS, TODD						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 4807 BOLLIG CT						Town of PORT EDWARDS				4807											
City NEKOOSA						State WI		Zip Code 54457				Street Address or Road Name and Number BOLLIG CT									
County Wood		Co. Permit # W26016		Notification # 10200006201		Completed 04-02-2026		Subdivision Name			Lot #		Block #								
Well Constructor (Business Name) ROCK SOLID WELL DRILLING LLC				Lic. # 9321		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2585 °N -89.9594 °W			Method Code SCR002								
Address 531 STATE HIGHWAY 73 NEKOOSA WI 54457				Well Plan Approval #		SE NW		Section 31		Township 21 N		Range 5 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well				of previous unique well # constructed in											
3. Well serves 1 # of CAMPER				Hicap Well ? No		Reason for replaced or reconstructed well ?															
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		38		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						N S C S Y		N-FINE S-SAND C-CLAY S-SANDY Y-SAND & GRAVEL		Surface 22 30		22 30 38			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				24 in. above grade							
5		F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED				Surface		32		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes							
5		S. S. #15				32		38		Pumping at 30 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Airlift											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No							
Method		TREMIE PIPE - PUMPED																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No													
20% SOLID PUMPABLE BENT		Surface		30		4 S															
SAND PACK		30		32		2 S															
RED FLINT GRAVEL PACK #30		32		38		4 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed					
JP														9099		04-05-2026					
Drill Rig Operator														Lic or Reg #		Date Signed					
JP														9099		04-05-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		150

Comment:

Created On: 04-05-2026

Updated On: 05-06-2026

Review Status: APPROVED