

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM461		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KRIECK, WERNER					Phone #		1. Well Location				Fire # (if avail.)								
Mailing Address 2092 PARADISE HILLS CT																			
City WEST BEND				State WI		Zip Code 53095		Town of TRENTON											
Street Address or Road Name and Number				2092 PARADISE HILLS CT															
County Washington		Co. Permit #		Notification # 10201836301		Completed 04-01-2026		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name)				Lic. # 435		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
ROSCI BROS WELL DRLG & PUMP INC								43.3992 °N -88.1402 °W				GPS008							
Address N10W28210 NORTHVIEW RD WAUKESHA WI 53188-9401				Well Plan Approval #		SW SW		Section 20		Township 11 N		Range 20 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 5		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		213		No Rotary - Mud Circulation		No		T		X		T-TAN/BROWN X-SAND & CLAY		Surface		48	
						No Rotary - Air		No		G		C		G-GRAY C-CLAY		48		137	
						No Rotary - Air & Foam		No		G		Z		G-GRAY Z-CLAY & GRAVEL		137		210	
						Yes Drill-Through Casing Hammer						L		L-LIMESTONE/DOLOMITE		210		213	
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				12 in. above grade					
6		BLACK STEEL PIPE WELDED JOINTS 18.97LB ASTM A53 1780PSI NUCOR				Surface		210		10. Pump Test				Developed ? Yes					
										Pumping level 40 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 25 GP M for 3 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No			
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No					
GRANULAR BENTONITE				Surface															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												TK				6203		04-01-2026	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												EK				8767		04-01-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		130	Septic or Holding, or POWTS Tank		103

Comment:

Created On: 04-06-2026

Updated On: 04-29-2026

Review Status: APPROVED