Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM461

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	KRIECK, WERNER
Phone #	
Mailing Address	2092 PARADISE HILLS CT
City	WEST BEND
State	WI
Zip Code	53095
County	Washington
Co. Permit #	
Notification #	10201836301
Completed	04-01-2026
Well Constructor (Business Name)	ROSCHI BROS WELL DRLG & PUMP INC
Lic. #	435
Facility ID # (Public Wells)	
Address	N10W28210 NORTHVIEW RD WAUKESHA WI 53188-9401
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	5

1. Well Location

Town of TRENTON

Fire # (if avail.)

Street Address or Road Name and Number: 2092 PARADISE HILLS CT

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.3992 °N -88.1402 °W	GPS008

SW	SW	Section	Township	Range
or Govt Lot #		20	11 N	20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	213

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		X		T-TAN/BROWN X-SAND & CLAY	Surface	48
G		C		G-GRAY C-CLAY	48	137
G		Z		G-GRAY Z-CLAY & GRAVEL	137	210
		L		L-LIMESTONE/DOLOMITE	210	213

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18.97LB ASTM A53 1780PSI NUCOR	Surface	210
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 25 GP M for 3 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TK	6203	04-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EK	8767	04-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		130	Septic or Holding, or POWTS Tank		103

Comment:

Created On: 04-06-2026 Updated On: 04-29-2026 Review Status: APPROVED