

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM466		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner NASI CONST				Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 13706 SKY BLUE LANE						Town of MANITOWISH WATERS				13706			
City MANITOWISH WATERS				State WI		Zip Code 54545				Street Address or Road Name and Number SKY BLUE LANE			
County Vilas		Co. Permit #		Notification # 10024292201		Completed 04-06-2026		Subdivision Name		Lot # Block #			
Well Constructor (Business Name) BINZ, STEVE E				Lic. # 3570		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.1476 °N -89.8745 °W		Method Code GPS008	
Address BINZ BROTHERS WELL DRILLING 6400 ODANAH RD HURLEY WI 54534-9736				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 4 42 N 5 E		2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable Borehole				Hicap Property ? No			
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		50		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
X		X-SAND & CLAY				Surface		40					
S		S-SAND				40		50					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL 18.97 LBS/FT WHEATLAND WELDED				Surface		44					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		SS ALLOY MACHINE 10 SLOT				44		50					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE		Surface		44		4 S							
9. Static Water Level													
21 ft. below ground surface													
10. Pump Test													
Pumping level 30 ft. below surface													
Pumping at 35 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
14 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
SB		3570		04-06-2026									
Drill Rig Operator		Lic or Reg #		Date Signed									
SB		7323		04-06-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		70	POWTS dispersal component (soil absorption unit or mound)		85

Comment:

Created On: 04-06-2026

Updated On: 04-29-2026

Review Status: APPROVED