Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM472

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PAUL RODEN			Phone #
Mailing Address: 917 WILLOW CT.			
City: SAUKVILLE	State: WI	Zip Code: 53012	
County: Ozaukee	Co. Permit #:	Notification #: 10210159901	Completed: 04-06-2026

Well Constructor (Business Name): GROTH WATER WELLS INC	Lic. #: 639	Facility ID # (Public Wells):	
Address: W69 N949 WASHINGTON AVE CEDARBURG WI 53012		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

1. Well Location

Town of SAUKVILLE				Fire # (if avail.): 2710
Street Address or Road Name and Number: 2710 HWY Y				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.37671 °N -88.03931 °W				Method Code: SCR002
SW NW or Govt Lot #:	Section: 31	Township: 11 N	Range: 21 E	

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of SHOP
Private,potable
Heat Exchange____# of drillholes
Drillhole
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	87
6	87	145

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X		X-SAND & CLAY	Surface	85
I	W	L		I-WHITE W-WATER BEARING L-LIMESTONE/DOLOMITE	85	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# ASTM A53 NUCOR P.E.	Surface	87
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 35 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method HALLIBURTON (SINGLE PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE 20% SOLIDS	Surface	87	4 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJG	8682	04-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-06-2026 Updated On: 05-08-2026 Review Status: APPROVED