

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM472		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PAUL RODEN					Phone #		1. Well Location Fire # (if avail.) 2710				
Mailing Address 917 WILLOW CT.											
City SAUKVILLE			State WI	Zip Code 53012		Town of SAUKVILLE					
Street Address or Road Name and Number						2710 HWY Y					
County Ozaukee		Co. Permit #	Notification # 10210159901		Completed 04-06-2026	Subdivision Name			Lot #	Block #	
Well Constructor (Business Name)			Lic. # 639	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code		
GROTH WATER WELLS INC					Well Plan Approval #		43.37671 °N	-88.03931 °W	SCR002		
Address W69 N949 WASHINGTON AVE CEDARBURG WI 53012			Approval Date (mm-dd-yyyy)		SW	NW	Section 31	Township 11 N	Range 21 E		
					or Govt Lot #						
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of SHOP				Hicap Well ? No							
Private, potable Drillhole				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
8	Surface	87	<u>Yes</u> Rotary - Mud Circulation				<u>No</u>				
6	87	145	<u>No</u> Rotary - Air				<u>Yes</u>				
			<u>No</u> Rotary - Air & Foam				<u>No</u>				
			<u>No</u> Drill-Through Casing Hammer								
			<u>No</u> Reverse Rotary								
			<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>				
			<u>No</u> Dual Rotary				<u>No</u>				
			<u>No</u> Temp. Outer Casing ___ in. dia								
			<u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
X		X-SAND & CLAY				Surface		85			
I W L		I-WHITE W-WATER BEARING L-LIMESTONE/DOLOMITE				85		145			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification			From (ft.)	To (ft.)	9. Static Water Level 9 ft. below ground surface			11. Well Is 28 in. above grade		
	Manufacturer & Method of Assembly										
6	18.97# ASTM A53 NUCOR P.E.			Surface	87	10. Pump Test Pumping level 40 ft. below surface Pumping at 35 GP M for 2 Hrs. Pumping Method ? Airlift			Developed ? Yes Disinfected ? Yes Capped ? Yes		
	Screen type, material & slot size										
7. Grout or Other Sealing Material											
Method HALLIBURTON (SINGLE PLUG)											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
BENTONITE 20% SOLIDS		Surface	87	4 S							
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
JJG						8682		04-16-2026			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-06-2026

Updated On: 05-08-2026

Review Status: APPROVED