Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM473

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JILEK, TRAVIS	Phone #: (715)874-6789
Mailing Address: 1350 CADEN COURT	
City: EAU CLAIRE	State: WI — Zip Code: 54703

County	Co. Permit #	Notification #	Completed
Eau Claire	35068	9917792101	04-04-2026

Well Constructor (Business Name): J & K PUMP & WELL SERVICE	Lic. #: 8364
Address: 20458 80TH AVE CADOTT WI 54727	

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.7

3. Well serves 1 # of BUILDING
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of UNION	Fire # (if avail.): 4901

Street Address or Road Name and Number: LYLE LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.8475 °N -91.5952 °W
Method Code: GPS008

NW SE or Govt Lot #	Section	Township	Range
	4	27 N	10 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	Y		T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL	Surface	100.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI WHEATLAND PIPE	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 10 SLOT	96.5	100.5

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 46 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JK	6336	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JK	6336	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	175
Building Drain - Sanitary	=	90
Sewer - Building Sanitary	=	150
Septic or Holding, or POWTS Tank	=	160

Comment:

Created On: 04-06-2026 Updated On: 05-29-2026 Review Status: APPROVED