Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM477

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ERIC VERWIEBE	Phone #
Mailing Address: N10W29863 ST. JAMES CT.	
City: WAUKESHA	State: WI — Zip Code: 53188
County: Waukesha	Co. Permit #: — Notification #: 10188856101 — Completed: 04-03-2026
Well Constructor (Business Name): KRIZAN, KENNETH J	Lic. #: 6519 — Facility ID # (Public Wells):
Address: 23900 W OVERSON RD, UNION GROVE WI 53182-9659	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location

Town of DELAFIELD

Fire # (if avail.):

Street Address or Road Name and Number: N10W29863 ST. JAMES CT.

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.0438 °N -88.3413 °W — Method Code: GPS008

NW or Govt Lot #	NW	Section	Township	Range
		26	7 N	18 E

2. Well Type Replacement

of previous unique well # MB245 constructed in 1997

Reason for replaced or reconstructed well ?: PUMP STUCK IN WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	319
6	319	745

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
No	Removed? 109depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	25
Y	Y-SAND & GRAVEL	25	55
Z	Z-CLAY & GRAVEL	55	109
L	L-LIMESTONE/DOLOMITE	109	113
H	H-SHALE	113	315
L	L-LIMESTONE/DOLOMITE	315	560
N	N-SANDSTONE	560	745

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
10	STUCK TEMP OUTER CASING	0	109
6	NUCORE ASTM A 53B 6.625X.280 FULL 20 WELDED	Surface	319
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GROUT (FLOAT) SHOE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	319	7.5 Y

9. Static Water Level

390 ft. below ground surface

10. Pump Test

Pumping level 720 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

WELL WILL BE SEALED BY AQUA WELL AND PUMP

Filled & Sealed Well(s) as needed? Yes

WELL WILL BE SEALED BY AQUA WELL AND PUMP

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK	6519	04-07-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-07-2026 Updated On: 10-15-2026 Review Status: APPROVED