

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM481		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner BICE TOM					Phone #		1. Well Location Fire # (if avail.) N19444					
Mailing Address N19332 ZIEGLER RD												
City DODGE			State WI		Zip Code 54625		Town of DODGE Street Address or Road Name and Number ZIEGLER RD					
County Trempealeau		Co. Permit # 1		Notification # 10214831701		Completed 04-09-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) FEDIE, DONALD S				Lic. # 127		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.1191 °N -91.4699 °W			Method Code GPS008	
Address FEDIE WELL DRILLING & PUMP SERVICE INC W536 U S HWY 10 MONDOVI WI 54755-7729				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 16 19 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 0								
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
10		Surface		30		No Rotary - Mud Circulation		No		K I K-BLACK I-SOIL-ORGANIC Surface 1 T C T-TAN/BROWN C-CLAY 1 20 T H N T-TAN/BROWN H-HARD/FIRM N-SANDSTONE 20 49		
6		30		49		No Rotary - Air		No				
						No Rotary - Air & Foam		No				
						No Drill-Through Casing Hammer						
						No Reverse Rotary						
						Yes Cable-tool Bit 10in. dia...		No				
						No Dual Rotary		No				
						No Temp. Outer Casing ___ in. dia						
						No Removed? ___ depth ft. (If NO explain on back side)						
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 15 ft. below ground surface		
6		STEEL PIPE 19.45 WHEATLAND T/C				Surface		31		11. Well Is 16 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No		
NEAT CEMENT GROUT				Surface		30		10 S		Filled & Sealed Well(s) as needed? No		
13. Constructor / Supervisory Driller												
DSF				Lic # 127		Date Signed 04-09-2026						
Drill Rig Operator				Lic or Reg # 7898		Date Signed 04-09-2026						
RG												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50	POWTS dispersal component (soil absorption unit or mound)		75
			Sewer - Building Sanitary		30

Comment:

Created On: 04-07-2026

Updated On: 05-06-2026

Review Status: APPROVED