Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM481

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BICE TOM	Phone #
Mailing Address: N19332 ZIEGLER RD	
City: DODGE	State: WI — Zip Code: 54625
County: Trempealeau	Co. Permit #: 1 — Notification #: 10214831701 — Completed: 04-09-2026
Well Constructor (Business Name): FEDIE, DONALD S	Lic. #: 127 — Facility ID # (Public Wells):
Address: FEDIE WELL DRILLING & PUMP SERVICE INC W536 U S HWY 10 MONDOVI WI 54755-7729	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Town of DODGE	Fire # (if avail.): N19444
Street Address or Road Name and Number: ZIEGLER RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1191 °N -91.4699 °W	Method Code: GPS008
NW SW or Govt Lot #:	Section: 16 — Township: 19 N — Range: 9 W

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	49

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		K-BLACK I-SOIL-ORGANIC	Surface	1
T		C		T-TAN/BROWN C-CLAY	1	20
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	20	49

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL PIPE 19.45 WHEATLAND T/C	Surface	31
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	30	10 S

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF	127	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed
RG	7898	04-09-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50	POWTS dispersal component (soil absorption unit or mound)		75
			Sewer - Building Sanitary		30

Comment:

Created On: 04-07-2026 Updated On: 10-15-2026 Review Status: APPROVED