

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM491		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RICHARDS CONSTRUCTION						Phone # (608)295-2740		1. Well Location				Fire # (if avail.)							
Mailing Address 4101 COMMERCIAL DRIVE								Town of HARMONY				5731							
City JANESVILLE						State WI		Zip Code 53545				Street Address or Road Name and Number							
5731 N HARVEST RIDGE DR MILTON WI 53563																			
County Rock		Co. Permit #		Notification # 10198153601		Completed 03-30-2026		Subdivision Name RESERVE AT STONEY RIDGE				Lot # 26		Block #					
Well Constructor (Business Name) BLOYER WELL & PUMP CO INC				Lic. # 87		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.75522 °N -88.99394 °W				Method Code SCR002					
Address 14312 FULMAR DR SOUTH BELOIT IL 61080-2399				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 5 3 N 13 E				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No													
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) 9.5		From (ft.) Surface		To (ft.) 124		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Yes Rotary - Mud Circulation				No		T X		T-TAN/BROWN X-SAND & CLAY		Surface		12	
						No Rotary - Air				No		T Y		T-TAN/BROWN Y-SAND & GRAVEL		12		26	
						No Rotary - Air & Foam				No		T C S		T-TAN/BROWN C-CLAY S-SANDY		26		44	
						No Drill-Through Casing Hammer						N S		N-FINE S-SAND		44		108	
						No Reverse Rotary						A Y		A-COARSE Y-SAND & GRAVEL		108		124	
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		53 ft. below ground surface				12 in. above grade					
5		SDR21 ASTM F480 PVC 200# WESTLAKE CERTA-LOK				Surface		120		10. Pump Test				Developed ? Yes					
										Pumping level 62 ft. below surface				Disinfected ? Yes					
										Pumping at 25 GP M for 1.5 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				No	
Method TREMIE PIPE - PUMPED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No					
CETCO QUICK GROUT				Surface		120		15 S											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
AES														6639		04-07-2026			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		38	POWTS dispersal component (soil absorption unit or mound)		73

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	05/04/2026	

Created On: 04-07-2026

Updated On: 05-04-2026

Review Status: APPROVED