Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM491

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARDS CONSTRUCTION	Phone #: (608)295-2740
Mailing Address: 4101 COMMERCIAL DRIVE	
City: JANESVILLE	State: WI — Zip Code: 53545

County	Co. Permit #	Notification #	Completed
Rock		10198153601	03-30-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BLOYER WELL & PUMP CO INC	87	

Address: 14312 FULMAR DR
SOUTH BELOIT IL 61080-2399

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		2.8

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of HARMONY

Fire # (if avail.): 5731

Street Address or Road Name and Number: 5731 N HARVEST RIDGE DR MILTON WI 53563

Subdivision Name	Lot #	Block #
RESERVE AT STONEY RIDGE	26	

Latitude / Longitude in Decimal Degree (DD): 42.75522 °N -88.99394 °W
Method Code: SCR002

NW or Govt Lot #	NW	Section	Township	Range
		5	3 N	13 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.5	Surface	124

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		X		T-TAN/BROWN X-SAND & CLAY	Surface	12
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	12	26
T		C	S	T-TAN/BROWN C-CLAY S-SANDY	26	44
	N	S		N-FINE S-SAND	44	108
	A	Y		A-COARSE Y-SAND & GRAVEL	108	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR21 ASTM F480 PVC 200# WESTLAKE CERTA-LOK	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	.020 STAINLESS STEEL WIRE WRAPPED JOHNSON .020 SLOT SCREEN	120	124

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO QUICK GROUT	Surface	120	15 S

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 62 ft. below surface
Pumping at 25 GP M for 1.5 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AES	6639	04-07-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		38	POWTS dispersal component (soil absorption unit or mound)		73

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	05/04/2026	

Created On: 04-07-2026 Updated On: 10-15-2026 Review Status: APPROVED