Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM497

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RIEDERER, JEFF	Phone #
Mailing Address: W311 CONCORD CENTER DR	
City: OCONOMOW	State: WI / Zip Code: 53066
County: Jefferson	Co. Permit #: / Notification #: 10200956901 / Completed: 03-27-2026
Well Constructor (Business Name): D&D WELL & PUMPS	Lic. #: 5694 / Facility ID # (Public Wells):
Address: N6331 COUNTY F, OCONOMOWOC WI 53066	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 1.4

1. Well Location

Town of CONCORD

Fire # (if avail.):

Street Address or Road Name and Number: W311 CONCORD CENTER DR

Subdivision Name: / Lot #: / Block #:

Latitude / Longitude in Decimal Degree (DD): 43.06335 °N -88.55148 °W

Method Code: GPS008

SE SW or Govt Lot #: / Section: 13 / Township: 7 N / Range: 16 E

2. Well Type New Well

of previous unique well #: / constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
F	F-FILL	Surface	5
S	S-SAND	5	42
X	X-SAND & CLAY	42	77
L	L-LIMESTONE/DOLOMITE	77	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97#, A53-B, NUCOR & WELDED	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJ	5694	04-07-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		56	POWTS dispersal component (soil absorption unit or mound)		78
			Sewer - Building Sanitary		33

Comment:

Created On: 04-07-2026 Updated On: 10-15-2026 Review Status: APPROVED