

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM497		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RIEDERER, JEFF					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address W311 CONCORD CENTER DR							Town of CONCORD						
City OCONOMOW					State WI		Zip Code 53066		Street Address or Road Name and Number				
							W311 CONCORD CENTER DR						
County Jefferson		Co. Permit #		Notification # 10200956901		Completed 03-27-2026		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) D&D WELL & PUMPS				Lic. # 5694		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.06335 °N -88.55148 °W			Method Code GPS008		
Address N6331 COUNTY F OCONOMOWOC WI 53066				Well Plan Approval #		SE SW		Section 13		Township 7 N		Range 16 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #			Common Well #			Specific Capacity 0			2. Well Type New Well				
									of previous unique well # constructed in				
									Reason for replaced or reconstructed well ?				
3. Well serves 1 # of HOME					Hicap Well ? No								
Private, potable					Hicap Property ? No								
Heat Exchange ___ # of drillholes					Hicap Potable ? No				Construction Type Drilled				
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		142		No Rotary - Mud Circulation			No				
						No Rotary - Air			No				
						No Rotary - Air & Foam			No				
						Yes Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...			No				
						No Dual Rotary			No				
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
F			F-FILL			Surface			5				
S			S-SAND			5			42				
X			X-SAND & CLAY			42			77				
L			L-LIMESTONE/DOLOMITE			77			142				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL, 18.97#, A53-B, NUCOR & WELDED				Surface		77					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface									
9. Static Water Level													
14 ft. below ground surface													
10. Pump Test													
Pumping level 28 ft. below surface													
Pumping at 20 GP M for 2 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
DJ				5694				04-07-2026					
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		56	POWTS dispersal component (soil absorption unit or mound)		78
			Sewer - Building Sanitary		33

Comment:

Created On: 04-07-2026

Updated On: 05-01-2026

Review Status: APPROVED