

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM510		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TOWN OF NEWTON						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N8309 COUNTY ROAD B						Town of NEWTON						N8309			
City WESTFIELD						State WI		Zip Code 53964				Street Address or Road Name and Number COUNTY ROAD B			
County Marquette		Co. Permit #		Notification # 10215925701		Completed 04-30-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) FARAGO, TERRY				Lic. # 41		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.94176 °N -89.44557 °W				Method Code GPS008	
Address N6079 8TH AVE PLAINFIELD WI 54966-9757				Well Plan Approval # Approval Date (mm-dd-yyyy)		NE SE		Section 17		Township 17 N		Range 9 E			
						or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NO WATER					
3. Well serves 1 # of TOWN HALL Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		123		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Y		Y-SAND & GRAVEL				Surface		31							
C		C-CLAY				31		65							
Y		Y-SAND & GRAVEL				65		90							
S N G		S-SOFT/LOOSE N-SANDSTONE G-W/GRAVEL/STONES				90		95							
S N		S-SOFT/LOOSE N-SANDSTONE				95		102							
H N		H-HARD/FIRM N-SANDSTONE				102		123							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 1,953.91				Surface		103							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		OPEN HOLE				103		123							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENT ALONG CASING				Surface											
9. Static Water Level															
8 ft. below ground surface															
10. Pump Test															
Pumping level 8 ft. below surface Pumping at 50 GP M for 1.5 Hrs. Pumping Method ? Airlift															
11. Well Is															
30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
TF				Lic # 41		Date Signed 05-13-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		52	POWTS dispersal component (soil absorption unit or mound)		67

Comment:

Created On: 04-08-2026

Updated On: 05-22-2026

Review Status: APPROVED