

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM513		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner DILEO, MICHEAL					Phone #		1. Well Location Fire # (if avail.) Town of NEWTON W5468 Street Address or Road Name and Number DIXIE LANE				
Mailing Address W5468 DIXIE LANE											
City WESTFIELD			State WI		Zip Code 53964		Subdivision Name CSM 2475				
County Marquette		Co. Permit #		Notification # 10216034801		Completed 04-24-2026					
Well Constructor (Business Name) FARAGO, TERRY				Lic. # 41		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.94476 °N -89.43365 °W		Method Code GPS008	
Address N6079 8TH AVE PLAINFIELD WI 54966-9757				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 16 17 N 9 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NO WATER Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #			Common Well #		Specific Capacity						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...	
6		Surface		100		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				S S-SAND Surface 10 C C-CLAY 10 15 Z Z-CLAY & GRAVEL 15 35 S N S-SOFT/LOOSE N-SANDSTONE 35 79 H N H-HARD/FIRM N-SANDSTONE 79 100	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
6		US NAPCO PVC NSF .480 SDR 21 SOLVENT WELD 1,517.60				Surface		80			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
6		OPEN HOLE				80		100			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement				
BENT ALONG CASING			Surface								
9. Static Water Level 4 ft. below ground surface											
10. Pump Test Pumping level 4 ft. below surface Pumping at 35 GP M for 1 Hrs. Pumping Method ? Airlift											
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
TF						41		04-27-2026			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		85	POWTS dispersal component (soil absorption unit or mound)		93

Comment:

Created On: 04-08-2026

Updated On: 05-22-2026

Review Status: APPROVED