Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM520

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LG CONSTRUCTION LLC		Phone #
Mailing Address: 203371 ICE AGE LN		
City: ROSHOLT	State: WI	Zip Code: 54473

County	Co. Permit #	Notification #	Completed
Portage		10204599601	04-01-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DJ'S WATER SERVICE	7072	

Address: 6522 OAK DR
AMHERST WI 54406

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		2.7

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Village of ROSHOLT

Fire # (if avail.): 340

Street Address or Road Name and Number: 340 SECOND ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.6298 °N	-89.3031 °W			GPS008

SW	NW	Section	Township	Range
or Govt Lot #		21	25 N	10 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	35
		C		C-CLAY	35	41
		Y		Y-SAND & GRAVEL	41	45
R		C		R-RED C-CLAY	45	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A53B 18.97 WHEATLAND WELD	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	15 SLOT STAINLESS STEEL TELESCOPING	41	45

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	41	1 S

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 24.3 ft. below surface
Pumping at 17 GP M for 12 Hrs.
Pumping Method ? Test Pump

11. Well Is
19 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJFJ	6760	04-01-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	04-01-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		25	Sewer - Building Sanitary		8

Comment:

Created On: 04-08-2026 Updated On: 05-06-2026 Review Status: APPROVED