

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM520		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LG CONSTRUCTION LLC						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 203371 ICE AGE LN						Village of ROSHOLT						340			
City ROSHOLT						State WI		Zip Code 54473				Street Address or Road Name and Number			
County Portage						Co. Permit #		Notification # 10204599601				Completed 04-01-2026			
Well Constructor (Business Name) DJ'S WATER SERVICE						Lic. # 7072		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6298 °N -89.3031 °W		Method Code GPS008	
Address 6522 OAK DR AMHERST WI 54406						Well Plan Approval #		SW NW		Section 21		Township 25 N		Range 10 E	
Hicap Permanent Well #						Common Well #		Specific Capacity 2.7				2. Well Type New Well		of previous unique well # constructed in	
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled		Heat Exchange ___ # of drillholes	
Private, potable						Hicap Property ? No									
Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		45		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
S		S-SAND						Surface		35					
C		C-CLAY						35		41					
Y		Y-SAND & GRAVEL						41		45					
R C		R-RED C-CLAY						45		45					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)							
6		STEEL A53B 18.97 WHEATLAND WELD				Surface		41							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		15 SLOT STAINLESS STEEL TELESCOPING				41		45							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		41		1 S							
9. Static Water Level															
18 ft. below ground surface															
10. Pump Test															
Pumping level 24.3 ft. below surface															
Pumping at 17 GP M for 12 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
19 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
DJFJ				6760				04-01-2026							
Drill Rig Operator				Lic or Reg #				Date Signed							
LM				7416				04-01-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		25	Sewer - Building Sanitary		8

Comment:

Created On: 04-08-2026

Updated On: 05-06-2026

Review Status: APPROVED