Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM528

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOSS	Phone #
Mailing Address: E10209A HAPPY LANE	
City: BARABOO	State: WI — Zip Code: 53913
County: Sauk	Co. Permit #: — Notification #: 10191958901 — Completed: 03-26-2026
Well Constructor (Business Name): HEZPAZ ENTERPRIZES	Lic. #: 8094 — Facility ID # (Public Wells):
Address: 3898 5TH DR, WISCONSIN DELLS WI 53965	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of DELTON	Fire # (if avail.): E10209A
Street Address or Road Name and Number: E10209A HAPPY LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.53462 °N -89.81265 °W	Method Code: SCR002
SE NW or Govt Lot #:	Section: 8 — Township: 12 N — Range: 6 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SAND POINT PLUGGED

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	48
1.25	48	51

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	N	S		Y-YELLOW N-FINE S-SAND	Surface	18
T	N	Y		T-TAN/BROWN N-FINE Y-SAND & GRAVEL	18	36
T	W	Y		T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL	36	51

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND A53 SCH 40 T&C	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAINLESS STEEL #80 GAUZE	48	51

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	47	0.5 S

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 7.5 GP M for 1.5 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HZ	3851	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		56	POWTS dispersal component (soil absorption unit or mound)		72

Comment:

Created On: 04-09-2026 Updated On: 10-15-2026 Review Status: APPROVED