

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM528		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner FOSS					Phone #			1. Well Location				Fire # (if avail.)							
Mailing Address E10209A HAPPY LANE								Town of DELTON				E10209A							
City BARABOO					State WI		Zip Code 53913		Street Address or Road Name and Number				E10209A HAPPY LANE						
County Sauk		Co. Permit #		Notification # 10191958901		Completed 03-26-2026		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) HEZPAZ ENTERPRIZES				Lic. # 8094		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.53462 °N -89.81265 °W				Method Code SCR002							
Address 3898 5TH DR WISCONSIN DELLS WI 53965				Well Plan Approval #		SE NW		Section 8		Township 12 N		Range 6 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type Replacement												
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? SAND POINT PLUGGED											
						Hicap Property ? No													
						Hicap Potable ? No		Construction Type Jetted											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
2		Surface		48		No Rotary - Mud Circulation		No		Y N S		Y-YELLOW N-FINE S-SAND		Surface		18			
1.25		48		51		No Rotary - Air		No		T N Y		T-TAN/BROWN N-FINE Y-SAND & GRAVEL		18		36			
						No Rotary - Air & Foam		No		T W Y		T-TAN/BROWN W-WATER BEARING Y-SAND & GRAVEL		36		51			
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		28 ft. below ground surface				14 in. above grade					
2		WHEATLAND A53 SCH 40 T&C				Surface		48		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes					
1.25		STAINLESS STEEL #80 GAUZE				48		51		Pumping at 7.5 GP M for 1.5 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes					
Method MOUNDED														Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
GRANULAR BENTONITE		Surface		47		0.5 S													
														13. Constructor / Supervisory Driller		Lic #		Date Signed	
														HZ		3851		04-09-2026	
														Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		56	POWTS dispersal component (soil absorption unit or mound)		72

Comment:

Created On: 04-09-2026

Updated On: 05-13-2026

Review Status: APPROVED