Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM529

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KASSNER	Phone #
Mailing Address: W12961 KASSNER ROAD	
City: WISCONSIN DELLS	State: WI — Zip Code: 53965
County: Columbia	Co. Permit #: — Notification #: 10200547601 — Completed: 03-27-2026
Well Constructor (Business Name): HEZPAZ ENTERPRIZES	Lic. #: 8094 — Facility ID # (Public Wells):
Address: 3898 5TH DR, WISCONSIN DELLS WI 53965	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of LEWISTON	Fire # (if avail.): W12961
Street Address or Road Name and Number: KASSNER ROAD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.64105 °N -89.64224 °W	Method Code: SCR002
NE NE or Govt Lot #: — Section: 3 — Township: 13 N — Range: 7 E	

2. Well Type Replacement
of previous unique well # LB322 constructed in
Reason for replaced or reconstructed well ?
OLD WELL CASING RUSTED
Construction Type: Jetted

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	42
1.25	42	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	S		T-TAN/BROWN M-MEDIUM S-SAND	Surface	38
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	38	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND A53 SCH 40 T&C	Surface	42
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	SSCSWR #7 SLOT W/ KPACKER	42	45

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	42	1 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 8 GP M for 2.5 Hrs.
Pumping Method ? Test Pump

11. Well Is
13 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HZ	3851	04-29-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		37	POWTS dispersal component (soil absorption unit or mound)		53

Comment:

Created On: 04-09-2026 Updated On: 10-15-2026 Review Status: APPROVED