Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM530

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DILLING, ANDY	Phone #: (920)850-1892
Mailing Address: 3065 WILLIAMS GRANT DR.	
City: DEPERE	State: WI — Zip Code: 54415
County: Marathon	Co. Permit #:
Notification #: 10162168901	Completed: 03-09-2026
Well Constructor (Business Name): BRUNNER WELL DRILLING LLC	Lic. #: 6469
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 303 S 8TH ST MEDFORD WI 54451	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of BERN

Fire # (if avail.):

Street Address or Road Name and Number: 245858 BEAVER CREEK ROAD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 45.0992 °N -90.1216 °W

Method Code: GPS008

SE NE or Govt Lot #: — Section: 10 — Township: 30 N — Range: 3 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	19
6	19	220

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL, T&C, A53B, 19.45#/FT., WHEATLAND, .280 WALL	Surface	98.7
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	19	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C	G	T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES	Surface	12
T		C	S	T-TAN/BROWN C-CLAY S-SANDY	12	35
T		C		T-TAN/BROWN C-CLAY	35	54
G	D	Q		G-GRAY D-DECOMPOSED/WEATHERED Q-GRANITE	54	60
R	H	Q		R-RED H-HARD/FIRM Q-GRANITE	60	98
G	H	Q		G-GRAY H-HARD/FIRM Q-GRANITE	98	220

9. Static Water Level	11. Well Is
9 ft. below ground surface	30 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 210 ft. below surface	Disinfected ? Yes
Pumping at 1.5 GP M for 12 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JWB	4379	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: 4A. NO SEPTIC TO DATE.

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		WE ARE THE PUMP INSTALLER AND SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED AND SYSTEM IS UP AND RUNNING.

Created On: 04-09-2026 Updated On: 05-04-2026 Review Status: APPROVED