

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM530		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner DILLING, ANDY						Phone # (920)850-1892					
Mailing Address 3065 WILLIAMS GRANT DR.											
City DEPERE				State WI		Zip Code 54415					
County Marathon		Co. Permit #		Notification # 10162168901		Completed 03-09-2026					
Well Constructor (Business Name) BRUNNER WELL DRILLING LLC						Lic. # 6469		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.0992 °N -90.1216 °W	
Address 303 S 8TH ST MEDFORD WI 54451						Well Plan Approval #		SE NE Section Township Range or Govt Lot # 10 30 N 3 E		Method Code GPS008	
						Approval Date (mm-dd-yyyy)					
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of CABIN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
10 Surface 19			No Rotary - Mud Circulation No			T C G T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES			Surface 12		
6 19 220			Yes Rotary - Air Yes			T C S T-TAN/BROWN C-CLAY S-SANDY			12 35		
			No Rotary - Air & Foam No			T C T-TAN/BROWN C-CLAY			35 54		
			No Drill-Through Casing Hammer			G D Q G-GRAY D-DECOMPOSED/WEATHERED Q-GRANITE			54 60		
			No Reverse Rotary			R H Q R-RED H-HARD/FIRM Q-GRANITE			60 98		
			No Cable-tool Bit ___ in. dia... No			G H Q G-GRAY H-HARD/FIRM Q-GRANITE			98 220		
			No Dual Rotary No								
			No Temp. Outer Casing ___ in. dia								
			No Removed? ___ depth ft. (If NO explain on back side)								
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		NEW BLACK STEEL, T&C, A53B, 19.45#/FT., WHEATLAND, .280 WALL				Surface		98.7			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
DRILLING MUD & CUTTINGS				Surface		19					

9. Static Water Level

9 ft. below ground surface

10. Pump Test

Pumping level 210 ft. below surface

Pumping at 1.5 GP M for 12 Hrs.

Pumping Method ? Test Pump

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

JWB

4379

04-09-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

4A. NO SEPTIC TO DATE.

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		WE ARE THE PUMP INSTALLER AND SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED AND SYSTEM IS UP AND RUNNING.

Created On: 04-09-2026

Updated On: 05-04-2026

Review Status: APPROVED